

Independence Fire Department
950 North Spring St.
Independence, MO 64050
816-325-7121



Tuesday, 23 February, 2021

Attn: Citlali Ray
Citlali Ray (Home Day Care)
1115 S Cottage Ave
Independence, MO 64055

Property Address:
Citlali Ray (Home Day Care)
1115 S Cottage Ave
Independence, MO 64055

Re: Initial - Home Daycare on February 23 2021

Congratulations, your business has satisfactorily completed and passed the Initial Home Daycare Fire and Life Safety Inspection. The Independence Missouri Fire Department would like to take this time to thank you for making fire safety a priority.

Upon satisfactory completion and signing off of all inspections by all required City Departments, your City of Independence, Missouri Business License will be sent to the business owner to be displayed within the occupancy.

Note: Records of inspection reports are maintained by the Fire Prevention Bureau of the City of Independence, Missouri Fire Department and are part of the public record requirements of the State of Missouri. It is possible that information contained in these reports in addition to your failure to correct any noted fire code violations may be used against you in civil and/or criminal proceedings in the event of an incident related to any such violation. These records may also be accessed by your insurance carrier.

Inspector:

Fire Inspector Robert Frazier

rfrazier@indepmo.org
816-325-7134

Property Representative:

Citlali Ray

Violation/Information Page(s)

General Inspection Information

Are address numbers on the building plainly legible and visible from the street fronting the property?

Pass

Are exit doors at least 28 wide?

Pass

Is a minimum 2A10BC portable fire extinguisher on the premises, mounted on a bracket near an exit, having a current inspection tag within the last 12 months?

Pass

Are smoke detectors provided in every area or room used for client sleeping purposes, outside of each separate sleeping area in the immediate vicinity of the bedrooms, and on each additional story of the family living unit including basements?

Pass

Does each room used for sleeping or dining purposes have at least two ways out?

Pass

Is every closet door operable from the inside by a client?

Pass

Is every bathroom door at least 24 wide?

Pass

Are special protective covers for electrical receptacles installed in all areas occupied by children?

Pass

Is every bathroom door lock operable from the outside with a readily accessible device ?

Pass

If children are permitted to be located in the basement are there two approved ways out?

Pass

Is heating equipment of an approved type, clean and in good working condition?

Pass

Is heating equipment in spaces occupied by clients provided with partitions, screens, or other means to protect children under six years of age from hot surfaces and open flames?

Pass

Are gas appliances equipped with a gas shut-off within 6 feet of the appliance?

Pass

Is at least one operable flashlight provided in an accessible location?

Pass

Is the hot water heater equipped with a relief valve and a drain line that extends between 6 to 24 from the floor?

Pass

Is storage of combustible materials maintained at least 36 from heat producing appliances such as furnaces, hot water heaters and dryers?

Pass

Are breaker/fuse boxes accessible and maintained with 30 inches in width, 36 inches depth and 78 inches in height of clear space in front of the panel with breakers free to operate?

Pass

Is electrical wiring free from hazardous conditions?

Pass
