

Independence Fire Department  
950 North Spring St.  
Independence, MO 64050  
816-325-7121



Tuesday, 23 February, 2021

Attn: Vanessa Kramer  
Vanessa Kramer (HOME DAY CARE)  
17229 E 40th St S  
Independence, MO 64055

Property Address:  
Vanessa Kramer (HOME DAY CARE)  
17229 E 40th St S  
Independence, MO 64055

Re: Initial - Home Daycare on February 23 2021

**Congratulations, your business has satisfactorily completed and passed the Initial Home Daycare Fire and Life Safety Inspection. The Independence Missouri Fire Department would like to take this time to thank you for making fire safety a priority.**

Upon satisfactory completion and signing off of all inspections by all required City Departments, your City of Independence, Missouri Business License will be sent to the business owner to be displayed within the occupancy.

*Note: Records of inspection reports are maintained by the Fire Prevention Bureau of the City of Independence, Missouri Fire Department and are part of the public record requirements of the State of Missouri. It is possible that information contained in these reports in addition to your failure to correct any noted fire code violations may be used against you in civil and/or criminal proceedings in the event of an incident related to any such violation. These records may also be accessed by your insurance carrier.*

Inspection Notes:

Looks good

Inspector:

Fire Inspector Robert Frazier

rfrazier@indepmo.org

816-325-7134

Property Representative:

Vanessa Kramer

**Violation/Information Page(s)**

**General Inspection Information**

**Are address numbers on the building plainly legible and visible from the street fronting the property?**

Pass

**Are exit doors at least 28 wide?**

Pass

**Is a minimum 2A10BC portable fire extinguisher on the premises, mounted on a bracket near an exit, having a current inspection tag within the last 12 months?**

Pass

**Are smoke detectors provided in every area or room used for client sleeping purposes, outside of each separate sleeping area in the immediate vicinity of the bedrooms, and on each additional story of the family living unit including basements?**

Pass

**Does each room used for sleeping or dining purposes have at least two ways out?**

Pass

**Is every closet door operable from the inside by a client?**

Pass

**Is every bathroom door at least 24 wide?**

Pass

**Are special protective covers for electrical receptacles installed in all areas occupied by children?**

Pass

**Is every bathroom door lock operable from the outside with a readily accessible device ?**

Pass

**If children are permitted to be located in the basement are there two approved ways out?**

Pass

**Is heating equipment of an approved type, clean and in good working condition?**

Pass

**Is heating equipment in spaces occupied by clients provided with partitions, screens, or other means to protect children under six years of age from hot surfaces and open flames?**

Pass

**Are gas appliances equipped with a gas shut-off within 6 feet of the appliance?**

Pass

**Is at least one operable flashlight provided in an accessible location?**

Pass

**Is the hot water heater equipped with a relief valve and a drain line that extends between 6 to 24 from the floor?**

Pass

**Is storage of combustible materials maintained at least 36 from heat producing appliances such as furnaces, hot water heaters and dryers?**

Pass

**Are breaker/fuse boxes accessible and maintained with 30 inches in width, 36 inches depth and 78 inches in height of clear space in front of the panel with breakers free to operate?**

Pass

**Is electrical wiring free from hazardous conditions?**

Pass

---