

Independence Fire Department
950 North Spring St.
Independence, MO 64050
816-325-7121



Friday, 22 October, 2021

Attn: Tim Blackwell
Tim Blackwell ** Short Term Rental **
1511 S Scott Ave
Independence, MO 64052

Property Address:
Tim Blackwell ** Short Term Rental **
1511 S Scott Ave
Independence, MO 64052

Re: Initial - Short Term Rental on October 22 2021

Congratulations, your business has satisfactorily completed and passed the Initial Short Term Rental Fire and Life Safety Inspection. The Independence Missouri Fire Department would like to take this time to thank you for making fire safety a priority.

Upon satisfactory completion and signing off of all inspections by all required City Departments, your City of Independence, Missouri Business License will be sent to the business owner to be displayed within the occupancy.

Note: Records of inspection reports are maintained by the Fire Prevention Bureau of the City of Independence, Missouri Fire Department and are part of the public record requirements of the State of Missouri. It is possible that information contained in these reports in addition to your failure to correct any noted fire code violations may be used against you in civil and/or criminal proceedings in the event of an incident related to any such violation. These records may also be accessed by your insurance carrier.

Inspector:

Fire Inspector Robert Frazier

rfrazier@indepmo.org
816-325-7134

Property Representative:

Tim Blackwell

Violation/Information Page(s)

General Inspection Information

Are address numbers plainly visible and legible from the street and in contrast with the background?

Pass

Is the way to the exit obvious and unobstructed?

Pass

Is there a map identifying escape routes posted in each guest room?

Pass

Is emergency contact information for the owner or manager posted in each guest room?

Pass

Is a new or properly tagged, minimum 2A10BC portable fire extinguisher mounted on a bracket in plain view and near an exit?

Pass

Are functioning smoke detectors present in each bedroom and common area?

Pass

Are child proofed electrical outlets or electrical outlet protectors installed in any unused outlet?

Pass

Is a functioning carbon monoxide detector present?

Pass

Are heating and refrigeration units maintained with proper 36" clearance from combustibles?

Pass

Is the hot water heater equipped with a relief valve and a drain line that extends between 6 to 24 from the floor?

Pass

Are breaker/fuse boxes accessible and maintained with 30 inches in width, 36 inches depth and 78 inches in height of clear space in front of the panel with breakers free to operate?

Pass
