



MEMORANDUM

DATE: February 8, 2022

TO: Zachary Walker, City Manager

THROUGH: Adam Norris, Assistant City Manager

FROM: Dan Montgomery, Water Systems Director

SUBJECT: ITB #22003 – Courtney Bend WTP Contact Basin No. 3 Protective Coating Systems Replacement – Water Department Project M22-708

It is Water Department Staff's recommendation that the bid submitted by Genesis Environmental Solutions, Inc. ("Genesis") in response to the City's Invitation to Bid #22003 for Water Department project M22-708 – Contact Basin 3 Coating Project at the Courtney Bend WTP in the amount of \$442,270.00 be accepted by the City.

This project shall provide for replacement of the protective coating system of Contact Basin No. 3 at the Courtney Bend Water Treatment Plant for the Water Department. The existing protective coating systems of the subject structure have reached the end of their effective service life. A protective coating system is required to protect the steel structures from damage caused by corrosion. If left unmitigated, corrosion could cause damage requiring costly repairs. New protective coating systems installed by this project are expected to provide protection from corrosion for approximately fifteen years. The Contact Basin No. 3 structure is a vital part of the Courtney Bend facility, and its capacity and capability to provide drinking water treatment.

This project was advertised as required, and City staff received two responsive bids. Upon review by Staff, it was determined the bid submitted by Genesis met all the requirements of the bid. Genesis possesses the necessary capability and capacity to perform this work, and has successfully completed similar projects for the Water Department recently.